

Leemco Flanged Tee - 4 x 4 x 4 Tee Flange x Flange x Flange w/ Base RGLFF-444TB





Details

All flanged fittings meet AWWA C515 standards. Constructed of ductile iron per ASTM A-536, Grade 65-45-12. Epoxy coating on all interior and exterior surfaces is fusion bonded epoxy, 12-14 mil thickness that passes 90-day immersion tests. Flanges are class 125.

Specifications

Manufacturer

Leemco

O.J. Company 294 Rang St-Paul Sherrington, JOL 2NO 450-247-2758